

May 13, 2022

Addendum #1

Washougal School District

Please note that this Addendum applies to RFP WSD-2022-T1

New documents have been posted to the web site reflecting the items below:

1. Washougal has decided to make the mandatory pre-bid optional. There will be an additional optional pre-bid on Wednesday, May 18, 2022 at 3:30pm.
2. Updated documents, pertaining to this Addendum, may be requested in the same manner as all documents. Please email diane.forbes@NIS.consulting and cc jessica.beehner@washougalsd.org.
3. For drawing revisions, see the attached Addendum 1 floorplans, dated 5/13/2022.
4. Specification Changes
 - a. 28 1000, Section 3.02.C Revised to read Disconnect magnetic door locks at cross corridor and exterior doors.(AD1)
 - b. 28 1000, Adds Section 3.03 MAGNETIC DOOR HOLDERS(AD1)
 - c. 28 1000, Adds Section 3.03.A Maintain current configuration to the cross corridor magnetic door holder power supplies.(AD1)

End of Addendum 1